



**ROOF SYSTEM ASSESSMENT REPORT
DYNAMIC UPLIFT RESISTANCE PER CSA A123.21**

CLIENT:	The Garland Company	TEST DATE:	2018-01-10
DOCUMENT NO.	GRL-PARS-1.3	PUBLICATION DATE:	2024-03-18
TEST PANEL NO.	GRL-D3	REVISION NO.	1
SYSTEM TYPE:	B	REEVALUATION DATE:	2027-03-18

PARTIALLY ADHERED ROOFING SYSTEM (PARS) SUMMARY

PERFORMANCE ⇒	PASSING PRESSURE	WIND UPLIFT RESISTANCE (RESISTANCE FACTOR 0.65)
	69 psf (3.3 kPa)	46 psf (2.2 kPa)

COMPONENT	ALLOWABLE PRODUCTS	
	PRODUCT	ATTACHMENT
SURFACING ⇒	(Optional) One of the following: 1. Minimum 400-lbs/100-ft. ² roofing gravel* in a flood coat of hot roofing asphalt at 60 lbs/square, or 2. Adhered surfacing options specified in UL Certifications under UL File TGFU.R8384 . *Refer to local Building Code for limitations concerning use of gravel surfacing.	
CAP PLY ⇒	StressPly IV, StressPly IV Mineral, StressPly IV UV Mineral, StressPly IV Plus, StressPly IV Plus UV Mineral or StressPly IV Plus Mineral	Torch-applied
BASE PLY ⇒	HPR Torch Base	Torch-applied
COVERBOARD ⇒	Min. 0.5-inch USG "SECUROCK Gypsum-Fiber Roof Board"	Hot asphalt at 25-30 lbs/square or InsulLock HR, continuous ribbons, 12-inch o.c.
INSULATION ⇒	One or more layer(s), top layer min. 2-inch thick, Atlas "ACFoam II", Hunter "H-Shield" or Johns Manville "ENRGY 3"	Topmost layer mechanically attached: ✓ Altenloh "Trufast #14 HD" with "Trufast 3" Metal Insulation Plate" ✓ OMG "#14 Roofgrip" with "OMG 3 in. Galvalume Steel Plate" or "AccuTrac Plate" ✓ SFS Group "Dekfast DF-#14-PH3" with "Dekfast PLT-H-2-7/8"
VAPOUR BARRIER ⇒	Grip-Rite Titan™ LD or other kraft paper or 6-mil polyethylene	Loose laid

ROOF SYSTEM ASSESSMENT REPORT, DYNAMIC UPLIFT RESISTANCE PER CSA A123.21

CLIENT:	The Garland Company	PUBLICATION DATE:	2024-03-18
DOCUMENT NO.	GRL-PARS-1.3	REVISION NO.	1
TEST PANEL NO.	GRL-D3	REEVALUATION DATE:	2027-03-18



Page 2 of 2

COMPONENT	ALLOWABLE PRODUCTS	
	PRODUCT	ATTACHMENT
THERMAL BARRIER (OPTIONAL) ⇒	Any type or thickness acceptable to the Authority Having Jurisdiction	Loose-laid, adhered or mechanically-attached
DECK ⇒	Minimum 22 ga. type B steel meeting ASTM A653, A792, A1008 or CSSBI 10M standards and having a yield strength of 275 MPa (40 ksi), or alternate steel deck providing the fastener withdrawal resistance noted below.	
INSULATION FASTENER POINT-LOAD ⇒	199 lbf (885 N)	

NEMO ETC CREDENTIALS		
TYPE	ENTITY	REFERENCE
ISO/IEC 17025 Accreditation	International Accreditation Service (IAS)	TL-689
TAS 301 Certification	Miami-Dade	21-0409.01
Third Party Test Data Program	UL, LLC	DA2862
Test Lab Listing	Roofing Contractors Association of British Columbia	RCABC Labs

REPORT HISTORY			
DATE	EVENT	NOTES	AUTHORIZED BY:
2018-02-27	FINAL	After customer review	RN
2024-03-18	REV1	3-year renewal	RN

This report and the data contained therein is the sole property of NEMO|etc. and the named client. This report shall not be reproduced outside NEMO|etc. except by the named client without written permission by the named client, in which case the report shall be reproduced in its entirety.

END OF REPORT