



ENGINEER

EVALUATE

TEST

CONSULT

**ROOF SYSTEM ASSESSMENT REPORT
DYNAMIC UPLIFT RESISTANCE PER CSA A123.21**

CLIENT:	SEAMAN CORPORATION	TEST DATE:	2020-06-11
DOCUMENT NO.	SMN-AARS-4	PUBLICATION DATE:	2023-07-20
TEST PANEL NO.	SMN-D11	REVISION NO.	3
SYSTEM TYPE:	A-1	REEVALUATION DATE:	2026-07-20

ADHESIVE APPLIED ROOFING SYSTEM (AARS) SUMMARY

PERFORMANCE⇒	PASSING PRESSURE	WIND UPLIFT RESISTANCE (with SF of 1.5)
		5.0 kPa (105 psf)

COMPONENT	ALLOWABLE PRODUCTS		BY
MEMBRANE⇒	<u>Option #1</u>	<u>Option #2</u>	Seaman Corporation
	FiberTite, FiberTite-SM, FiberTite-XT or FiberTite XTreme	FiberTite FB, FiberTite-SM FB, FiberTite-XT FB or FiberTite XTreme FB	
ATTACHMENT:	<u>For Option #1</u>	<u>For Option #2</u>	Seaman Corporation
	FTR-190e, contact application, 0.5 gal./sq. per surface or Alpha-Tite Bonding Adhesive, contact application, 0.83 to 1.0 gal./sq. per surface	FTR-290 or FTR-390 at 1 gal./sq.	
		Polyset CR-20, spatter-application	ICP Adhesives & Sealants
INSULATION, TOP LAYER⇒	max. 4 x 4-ft. x min. 1.5-inch thick		
	FTR-Value or FTR-Value H		Seaman Corporation
	ACFoam II		Atlas Roofing
	H-Shield		Hunter Panels
	ISOLEX A		Lexsuco 2010 Corp
ATTACHMENT:	ASTM D312, Type II or IV asphalt	25-30 lbs/sq.	various
INSULATION, BASE LAYER(S)⇒	Optional, one or more layers, max. 4 x 4-ft. x min. 1.5-inch thick		
	FTR-Value or FTR-Value H		Seaman Corporation
	ACFoam II		Atlas Roofing
	H-Shield		Hunter Panels
	ISOLEX A		Lexsuco 2010 Corp
ATTACHMENT:	ASTM D312, Type III or IV asphalt	25-30 lbs/sq.	various

ROOF SYSTEM ASSESSMENT REPORT, DYNAMIC UPLIFT RESISTANCE PER CSA A123.21

CLIENT: SEAMAN CORPORATION PUBLICATION DATE: 2023-07-20
 DOCUMENT NO. SMN-AARS-4 REVISION NO. 3
 TEST PANEL NO. SMN-D11 REEVALUATION DATE: 2026-07-20
 Page 2 of 2



COMPONENT	ALLOWABLE PRODUCTS	BY
VAPOUR BARRIER⇒	FiberTite-SBS TG Base or FiberTite-SBS 190 TG Base	Seaman Corporation
ATTACHMENT:	torch-applied	
PRIMER⇒	ASTM D41 primer, 0.5 gal./100 ft2	various
DECK⇒	Min. 2,500 psi structural concrete	generic

NEMO ETC CREDENTIALS

TYPE	ENTITY	REFERENCE
ISO/IEC 17025 Accreditation	International Accreditation Service (IAS)	TL-689
TAS 301 Certification	Miami-Dade	21-0409.01
Third Party Test Data Program	UL, LLC	DA2862
Test Lab Listing	Roofing Contractors Association of British Columbia	www.rcabc.org

REPORT HISTORY

DATE	EVENT	NOTES	AUTHORIZED BY:
2020-08-24	FINAL issued	After client review	RN
2020-12-29	REV1 issued	Add ISOLEX A Correct Option #2 membrane designations.	RN
2021-10-20	REV2 issued	Add AlphaTite Bonding Adhesive	RN
2021-07-20	REV3 issued	Renewal after verification	RN

This report and the data contained therein is the sole property of NEMO|etc. and the named client. This report shall not be reproduced outside NEMO|etc. except by the named client without written permission by the named client, in which case the report shall be reproduced in its entirety.

END OF REPORT