



ENGINEER

TEST

CONSULT

ROOF SYSTEM ASSESSMENT REPORT DYNAMIC UPLIFT RESISTANCE PER CSA A123.21			
CUSTOMER:	Tremco CPG, Inc.	TEST DATE:	2019-02-15, 2021-03-26 & 2021-07-09
DOCUMENT NO.	TRM-AARS-4.1	PUBLICATION DATE:	2024-08-05
TEST PANEL NO.	TRM-D4 + TRM-D6 + TRM-D7	REVISION NO.	0
SYSTEM TYPE:	A-1	REEVALUATION DATE:	2027-08-05

ADHESIVE APPLIED ROOFING SYSTEM (AARS) SUMMARY		
PERFORMANCE ⇒	PASSING PRESSURE	WIND UPLIFT RESISTANCE (RESISTANCE FACTOR 0.65)
	105 psf (5.0 kPa)	70 psf (3.4 kPa)

COMPONENT	ALLOWABLE PRODUCTS	
	PRODUCT	ATTACHMENT
SURFACING ⇒	(Optional) Any Tremco hot-applied or cold-applied flood coat and gravel or aggregate stone*, or Tremco roof coating approved for use with the cap ply membrane, applied in accordance with Tremco requirements. *Refer to local Building Code for limitations concerning use of gravel surfacing.	
CAP PLY ⇒	BURmastic Composite Ply HT, BURmastic Composite Ply Premium, BURmastic Composite Ply HT Green, POWERply Endure 300 Smooth, POWERply Endure 320 Smooth, POWERply Standard Smooth, POWERply Endure 100 Smooth, POWERply Heavy Duty Base, POWERply 2PM, POWERply Endure 200 Smooth, POWERply Endure 300 FR, POWERply Endure 320 FR, POWERply Standard, POWERply Standard FR, POWERply Standard FR GT24C, POWERply Endure 100 FR, POWERply 3GR or POWERply Endure 200 FR	BURmastic Adhesive MC at full-coverage, 2.0 gal/square.
PLY ⇒	(Optional) BURmastic Composite Ply HT, BURmastic Composite Ply Premium, BURmastic Composite Ply HT Green, POWERply Endure 300 Smooth, POWERply Endure 320 Smooth, POWERply Standard Smooth, POWERply Endure 100 Smooth, POWERply Heavy Duty Base, POWERply 2PM or POWERply Endure 200 Smooth	BURmastic Adhesive MC at full-coverage, 2.0 gal/square.
BASE PLY ⇒	BURmastic Composite Ply HT, BURmastic Composite Ply Premium, BURmastic Composite Ply HT Green, POWERply Endure 300 Smooth, POWERply Endure 320 Smooth, POWERply Standard Smooth, POWERply Endure 100 Smooth, POWERply Heavy Duty Base, POWERply 2PM or POWERply Endure 200 Smooth	BURmastic Adhesive MC at full-coverage, 2.0 gal/square.

ROOF SYSTEM ASSESSMENT REPORT, DYNAMIC UPLIFT RESISTANCE PER CSA A123.21

CUSTOMER:	Tremco CPG, Inc.	PUBLICATION DATE:	2024-08-05
DOCUMENT NO.	TRM-AARS-4.1	REVISION NO.	0
TEST PANEL NO.	TRM-D4+D6+D7	REEVALUATION DATE:	2027-08-05



Page 2 of 2

COMPONENT	ALLOWABLE PRODUCTS	
	PRODUCT	ATTACHMENT
COVERBOARD ⇒	Min. 0.5-inch Building Products of Canada Corp. “BP ESGARD High Density Roof Insulator, coated with asphalt on 6 sides”, G-P Gypsum “DensDeck Prime” or USG “SECUROCK Gypsum-Fiber Roof Board”	Tremco Low Rise Foam Insulation Adhesive or Low Rise Foam Insulation Adhesive (BG) or HB Fuller “Millennium One Step Foamable Adhesive” or “Millennium PG-1 Pump Grade Adhesive”, continuous ribbons, 6-inch o.c. or THERMastic 80 or hot asphalt at 25-30 lbs/sq.
INSULATION, BASE LAYER(S) ⇒	(Optional) One or more layers, min. 1-inch x max. 4x4 ft Trisotech, Trisotech G, Trisotech CGF, Atlas Roofing “ACFoam II” or “ACFoam III” or Johns Manville “ENRGY 3”	Tremco Low Rise Foam Insulation Adhesive or Low Rise Foam Insulation Adhesive (BG) or HB Fuller “Millennium One Step Foamable Adhesive” or “Millennium PG-1 Pump Grade Adhesive”, continuous ribbons, 6-inch o.c. or THERMastic 80 or hot asphalt at 25-30 lbs/sq.
VAPOUR BARRIER ⇒	BURmastic Composite Ply HT or BURmastic Composite Ply Premium	BURmastic Adhesive MC at full-coverage, 2.0 gal/square or THERMastic 80 or hot asphalt at 25-30 lbs/square.
DECK ⇒	Min. 2,500 psi structural concrete	

RSAR SCOPE

Roof System Assessment Reports (RSAR) constitute a summary of allowable products and interfaces used in low-slope roof assemblies based testing in accordance with CSA A123.21 at our ISO/IEC 17025 accredited laboratory.

While RSAR's are reviewed and renewed each 3-years based primarily on report holder declaration, these are not Certification listings, and are not intended to state or imply ongoing quality control / surveillance activities by NEMO at the report holder's facilities.

NEMO ETC, LLC is not, in any way, the Designer of Record for any project on which these RSAR's, or previous versions thereof, is/was used for permitting or design guidance. RSAR's are not to be construed as representing any attributes not specifically listed, nor to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by NEMO ETC, LLC, express or implied, as to any finding or other matter in these RSAR's, or as to any product covered by the RSAR's.

NEMO ETC CREDENTIALS

TYPE	ENTITY	REFERENCE
ISO/IEC 17025 Accreditation	International Accreditation Service (IAS)	TL-689
TAS 301 Certification	Miami-Dade	21-0409.01
Third Party Test Data Program	UL, LLC	DA2862
Test Lab Listing	Roofing Contractors Association of British Columbia	RCABC Labs

REPORT HISTORY

DATE	EVENT	NOTES	AUTHORIZED BY:
2024-08-05	FINAL	None	RN

This report and the data contained therein is the sole property of NEMO|etc. and the named client. This report shall not be reproduced outside NEMO|etc. except by the named client without written permission by the named client, in which case the report shall be reproduced in its entirety.

END OF REPORT