



NEMO|etc.

353 Christian Street, Unit #13
Oxford, CT 06478
(203) 262-9245

ENGINEER

TEST

CONSULT

ROOF SYSTEM ASSESSMENT REPORT DYNAMIC UPLIFT RESISTANCE PER CSA A123.21			
CUSTOMER:	Tremco CPG, Inc.	TEST DATES:	2025-09-19, 2025-09-29 (by others)
DOCUMENT NO.	TRM-PARS-7.1	PUBLICATION DATE:	2025-10-27
TEST PANEL NO.	TRM-D14 + TRM-D15 + TRM-D1	REVISION NO.	0
NEMO TYPE:	B-1	REEVALUATION DATE:	2028-10-27

PARTIALLY ADHERED ROOFING SYSTEM (PARS) SUMMARY

ROOFING SYSTEM SUMMARY:	
NEMO Type:	B-1; Mechanically Fixed Insulation, Bonded Coverboard; Bonded Roof Cover
Cap Ply:	Oxidized asphaltic sheet or SBS modified bitumen, cold-adhesive applied
Ply:	(Optional) Oxidized asphaltic sheet or SBS modified bitumen, cold-adhesive applied
Base Ply:	Oxidized asphaltic sheet or SBS modified bitumen, cold-adhesive applied
Coverboard:	Wood fiber board, adhesive-applied
Insulation (mid):	(Optional) Polyisocyanurate foam board, adhesive-applied
Insulation (base):	Polyisocyanurate foam board, mechanically fixed
Vapor Barrier:	Any approved type, loose-laid, adhered or mechanically fixed
Thermal Barrier:	(Optional) Any approved type, loose-laid, adhered or mechanically fixed
Deck:	Wood or steel

DYNAMIC UPLIFT RESISTANCE PER CSA A123.21:					
Sustained Test Value		Design Value CSA A123.21:20 (Test Value x 0.65)		Design Value CSA A123.21:14 (Test Value ÷ 1.5)	
kPa	psf	kPa	psf	kPa	psf
-3,0	-63	-2,0	-41	-2,0	-42

PRODUCTS / APPLICATION:		
Surfacing: (Optional)	Description:	Surfacing applied for fire classification performance and/or reflectivity.
	Application:	Cold-applied, hot-applied or fluid-applied
	Eligible Products:	Any Tremco hot-applied or cold-applied flood coat and gravel or aggregate stone, or Tremco roof coating approved for use with the cap ply membrane, applied in accordance with Tremco requirements.
Cap Ply:	Description:	Membrane composed of fiberglass reinforcement coated with oxidized bitumen or fiberglass, fiberglass/polyester composite or polyester reinforcement coated with SBS modified bitumen
	Application:	BURmastic Adhesive or POWERply Standard Cold Adhesive, full-coverage, 2.0 gal/square
	Eligible Products:	BURmastic Glass Ply, BURmastic Glass Ply – 28 lb, BURmastic Composite Ply HT, BURmastic Composite Ply Premium, BURmastic Composite Ply HT Green, POWERply Standard Smooth, POWERply Heavy Duty Base, POWERply 2PM, POWERply Endure 300 FR, POWERply Endure 320 FR, POWERply Standard, POWERply Standard FR, POWERply Standard FR GT24C, POWERply Endure 100 FR, POWERply 3GR or POWERply Endure 200 FR

ROOF SYSTEM ASSESSMENT REPORT, DYNAMIC UPLIFT RESISTANCE PER CSA A123.21

CUSTOMER:	Tremco CPG, Inc.	PUBLICATION DATE:	2025-10-27
DOCUMENT NO.	TRM-PARS-7.1	REVISION NO.	0
		REEVALUATION DATE:	2028-10-27



PRODUCTS / APPLICATION:																				
Ply: (Optional)	Description:	Membrane composed of fiberglass reinforcement coated with oxidized bitumen or fiberglass, fiberglass/polyester composite or polyester reinforcement coated with SBS modified bitumen																		
	Application:	BURmastic Adhesive or POWERply Standard Cold Adhesive, full-coverage, 2.0 gal/square																		
	Eligible Products:	One or more BURmastic Glass Ply, BURmastic Glass Ply – 28 lb, BURmastic Composite Ply HT, BURmastic Composite Ply Premium, BURmastic Composite Ply HT Green, POWERply Endure 300 Smooth, POWERply Endure 320 Smooth, POWERply Standard Smooth, POWERply Endure 100 Smooth, POWERply Heavy Duty Base, POWERply 2PM or POWERply Endure 200 Smooth																		
Base Ply:	Description:	Membrane composed of fiberglass reinforcement coated with oxidized bitumen or fiberglass, fiberglass/polyester composite or polyester reinforcement coated with SBS modified bitumen																		
	Application:	BURmastic Adhesive or POWERply Standard Cold Adhesive, full-coverage, 2.0 gal/square																		
	Eligible Products:	BURmastic Glass Ply, BURmastic Glass Ply – 28 lb, BURmastic Composite Ply HT, BURmastic Composite Ply Premium, BURmastic Composite Ply HT Green, POWERply Endure 300 Smooth, POWERply Endure 320 Smooth, POWERply Standard Smooth, POWERply Endure 100 Smooth, POWERply Heavy Duty Base, POWERply 2PM or POWERply Endure 200 Smooth																		
Coverboard:	Description:	Wood fiber board																		
	Application:	Adhesive-applied																		
	Eligible Products:	<table border="1"> <thead> <tr> <th>By</th> <th>Product</th> <th>Thickness</th> </tr> </thead> <tbody> <tr> <td>Blue Ridge Fiberboard</td> <td>StructoDek High Density Fiberboard Roof Insulation</td> <td>Min. 12.7-mm (0.5-inch)</td> </tr> </tbody> </table>	By	Product	Thickness	Blue Ridge Fiberboard	StructoDek High Density Fiberboard Roof Insulation	Min. 12.7-mm (0.5-inch)												
By	Product	Thickness																		
Blue Ridge Fiberboard	StructoDek High Density Fiberboard Roof Insulation	Min. 12.7-mm (0.5-inch)																		
Coverboard Adhesive:	Description:	Polyurethane based insulation adhesive																		
	Application Rate:	Continuous ribbons, max. 305-mm (12-inch) on-center																		
	Eligible Products:	<table border="1"> <thead> <tr> <th>By</th> <th>Product</th> </tr> </thead> <tbody> <tr> <td>Tremco CPG</td> <td>Low Rise Foam Insulation Adhesive, Low Rise Foam Insulation Adhesive (BG) or Tremco PSF Adhesive</td> </tr> <tr> <td>HB Fuller Company</td> <td>Millennium One Step Foamable Adhesive or Millennium PG-1 Pump Grade Adhesive</td> </tr> </tbody> </table>	By	Product	Tremco CPG	Low Rise Foam Insulation Adhesive, Low Rise Foam Insulation Adhesive (BG) or Tremco PSF Adhesive	HB Fuller Company	Millennium One Step Foamable Adhesive or Millennium PG-1 Pump Grade Adhesive												
		By	Product																	
Tremco CPG	Low Rise Foam Insulation Adhesive, Low Rise Foam Insulation Adhesive (BG) or Tremco PSF Adhesive																			
HB Fuller Company	Millennium One Step Foamable Adhesive or Millennium PG-1 Pump Grade Adhesive																			
Insulation, mid layer(s): (Optional)	Description:	Polyisocyanurate foam board laminated on both sides with fiber reinforced felt or coated fiberglass facer																		
	Application:	One or more layer(s), adhesive-applied																		
	Eligible Products:	<table border="1"> <thead> <tr> <th>By</th> <th>Product</th> <th>Dimensions</th> </tr> </thead> <tbody> <tr> <td>Tremco CPG</td> <td>Trisotech, Trisotech G or Trisotech CGF</td> <td rowspan="6">Max. 1.2 x 1.2-m (4 x 4 ft) x min. 25-mm (1-inch) thick</td> </tr> <tr> <td>Amrize / Elevate</td> <td>ISOGARD GL or ISOGARD CG</td> </tr> <tr> <td>Atlas Roofing</td> <td>ACFoam II or ACFoam III</td> </tr> <tr> <td>GAF</td> <td>EnergyGuard Polyiso Insulation</td> </tr> <tr> <td>Hunter Panels</td> <td>H-Shield</td> </tr> <tr> <td>Johns Manville</td> <td>ENRGY 3</td> </tr> <tr> <td>Rmax Ltd</td> <td>Multi-Max FA3 or UltraMax</td> </tr> </tbody> </table>	By	Product	Dimensions	Tremco CPG	Trisotech, Trisotech G or Trisotech CGF	Max. 1.2 x 1.2-m (4 x 4 ft) x min. 25-mm (1-inch) thick	Amrize / Elevate	ISOGARD GL or ISOGARD CG	Atlas Roofing	ACFoam II or ACFoam III	GAF	EnergyGuard Polyiso Insulation	Hunter Panels	H-Shield	Johns Manville	ENRGY 3	Rmax Ltd	Multi-Max FA3 or UltraMax
		By	Product	Dimensions																
		Tremco CPG	Trisotech, Trisotech G or Trisotech CGF	Max. 1.2 x 1.2-m (4 x 4 ft) x min. 25-mm (1-inch) thick																
		Amrize / Elevate	ISOGARD GL or ISOGARD CG																	
		Atlas Roofing	ACFoam II or ACFoam III																	
GAF		EnergyGuard Polyiso Insulation																		
Hunter Panels	H-Shield																			
Johns Manville	ENRGY 3																			
Rmax Ltd	Multi-Max FA3 or UltraMax																			

ROOF SYSTEM ASSESSMENT REPORT, DYNAMIC UPLIFT RESISTANCE PER CSA A123.21

CUSTOMER: Tremco CPG, Inc. PUBLICATION DATE: 2025-10-27
 DOCUMENT NO. TRM-PARS-7.1 REVISION NO. 0
 REEVALUATION DATE: 2028-10-27



PRODUCTS / APPLICATION:				
Insulation, mid layer, Adhesive:	Description:	Polyurethane based insulation adhesive		
	Application:	Continuous ribbons, max. 305-mm (12-inch) on-center		
	Eligible Products:	By	Product	
		Tremco CPG	Low Rise Foam Insulation Adhesive, Low Rise Foam Insulation Adhesive (BG) or Tremco PSF Adhesive	
HB Fuller Company	Millennium One Step Foamable Adhesive or Millennium PG-1 Pump Grade Adhesive			
Insulation, base layer:	Description:	Polyisocyanurate foam board laminated on both sides with fiber reinforced felt or coated fiberglass facer		
	Dimensions:	Min. 1.2 x 2.4-m (4 x 8 ft) or 1.2 x 1.2-m (4 x 4 ft) x thickness noted below		
	Application:	Optional base layer(s) loose laid, top layer mechanically fixed		
	Eligible Products:	By	Products	Min. Top Layer Thickness 50.8-mm (2-inch)
		Tremco CPG	Trisotech, Trisotech G or Trisotech CGF	
		Amrize / Elevate	ISOGARD GL or ISOGARD CG	
		Atlas Roofing	ACFoam II or ACFoam III	
		GAF	EnergyGuard Polyiso Insulation	
Hunter Panels		H-Shield		
Johns Manville		ENRGY 3		
Rmax Ltd	Multi-Max FA3 or UltraMax			
Insulation Fasteners:	Description:	Corrosion resistant screw-type roofing fasteners with steel stress plates		
	Fastening Method:	Fasteners installed through stress plates to engage the top flanges of the steel deck		
	Fastener Density:	1 per 2 ft ² (16 parts per 4x8 ft board or 8 parts per 4x4 ft board)		
	Eligible Products:	By		Product
		Tremco CPG		Tremco #12 DP, Tremco #14 HD or Tremco #15 EHD with Tremco 3" Metal Insulation Plate
Altenloh, Brink & Co US		Trufast #12 DP, Trufast #14 HD or Trufast #15 EHD with Trufast 3" Metal Insulation Plate		
OMG	OMG #12 Standard Roofgrip, OMG #14 Heavy Duty or OMG XHD with OMG 3 in. Ribbed Galvalume Plate			

ROOF SYSTEM ASSESSMENT REPORT, DYNAMIC UPLIFT RESISTANCE PER CSA A123.21

CUSTOMER:	Tremco CPG, Inc.	PUBLICATION DATE:	2025-10-27
DOCUMENT NO.	TRM-PARS-7.1	REVISION NO.	0
		REEVALUATION DATE:	2028-10-27



PRODUCTS / APPLICATION:		
Vapour Barrier: <i>(Optional)</i>	Description:	Min. 6-mil polyethylene or other vapor barrier
	Application:	Loose-laid, adhered or mechanically-attached
	Eligible Products:	Any approved product acceptable to Tremco and the Authority Having Jurisdiction
Thermal Barrier: <i>(Optional)</i>	Description:	Cement-based, gypsum-based or mineral-wool board
	Application:	Loose-laid, adhered or mechanically-attached
	Eligible Products:	Any approved product acceptable to Tremco and the Authority Having Jurisdiction
Deck:	As-Tested:	Plywood roof deck
	Extended:	Steel roof deck

NOTES:				
Test Value and Design Value:	The "Test Value" noted herein reflects the ultimate passing test pressure recorded during testing. The "Design Value" herein reflects the "Test Value" multiplied by a resistance factor of 0.65, or divided by a safety factor of 1.5. The "Design Value" should meet or exceed the design pressure requirements of the project, as determined in accordance with the current National Building Code of Canada (NBC) requirements.			
Equivalence of Other Products:	This report applies only to the products listed as "Eligible Products" herein.			
Optional Components:	Components listed herein as "optional" may be removed from the roof system design with no adverse effect on system dynamic wind uplift performance.			
As-Tested Deck:	Testing utilized plywood, APA rated sheathing, 40/20, Exposure 1, PS1, 19/32 category, CDX. Results extended to use of min. 22 ga., Type B (6-inch deck module) steel deck meeting ASTM A653, A792, A1008 or CSSBI 10M standard and having a yield strength of 275 MPa (40-ksi) based on previous testing (TRM-D1). Alternate deck displaying equivalent strength and fastener-holding capacity (withdrawal resistance) may be specified at the discretion of the Designer of Record to the satisfaction of the Authority Having Jurisdiction.			
Fastener Point-Loads:	Point-Load			
	Sustained Test Value		Design Value	
	N	lbf	N	lbf
	560	126	364	82

ROOF SYSTEM ASSESSMENT REPORT, DYNAMIC UPLIFT RESISTANCE PER CSA A123.21

CUSTOMER:	Tremco CPG, Inc.	PUBLICATION DATE:	2025-10-27
DOCUMENT NO.	TRM-PARS-7.1	REVISION NO.	0
		REEVALUATION DATE:	2028-10-27



RSAR SCOPE

Roof System Assessment Reports (RSAR) constitute a summary of allowable products and interfaces used in low-slope roof assemblies based testing in accordance with CSA A123.21 at our ISO/IEC 17025 accredited laboratory.

While RSAR's are reviewed and renewed each 3-years based primarily on report holder declaration, these are not Certification listings, and are not intended to state or imply ongoing quality control / surveillance activities by NEMO at the report holder's facilities.

NEMO ETC, LLC is not, in any way, the Designer of Record for any project on which these RSAR's, or previous versions thereof, is/was used for permitting or design guidance. RSAR's are not to be construed as representing any attributes not specifically listed, nor to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by NEMO ETC, LLC, express or implied, as to any finding or other matter in these RSAR's, or as to any product covered by the RSAR's.

NEMO ETC CREDENTIALS

TYPE	ENTITY	REFERENCE
ISO/IEC 17025 Accreditation	International Accreditation Service (IAS)	TL-689
TAS 301 Certification	Miami-Dade	21-0409.01
Third Party Test Data Program	UL, LLC	DA2862
Test Lab Listing	Roofing Contractors Association of British Columbia	RCABC Labs

REPORT HISTORY

DATE	EVENT	NOTES	AUTHORIZED BY:
2025-10-24	DRAFT 1	For customer review	RN
2025-10-27	FINAL	After customer review	RN

This report and the data contained therein is the sole property of NEMO|etc. and the named customer. This report shall not be reproduced outside NEMO|etc. except by the named customer without written permission by the named customer, in which case the report shall be reproduced in its entirety.

END OF REPORT