



**NEMO|etc.**

353 Christian Street, Unit #13  
Oxford, CT 06478  
(203) 262-9245

ENGINEER

TEST

CONSULT

ROOF SYSTEM ASSESSMENT REPORT DYNAMIC UPLIFT RESISTANCE PER CSA A123.21			
CUSTOMER:	<a href="#">Tremco CPG, Inc.</a>	TEST DATES:	2025-09-19 (by others)
DOCUMENT NO.	TRM-PARS-7	PUBLICATION DATE:	2025-10-27
TEST PANEL NO.	TRM-D14 + TRM-D1	REVISION NO.	0
NEMO TYPE:	B-1	REEVALUATION DATE:	2028-10-27

**PARTIALLY ADHERED ROOFING SYSTEM (PARS) SUMMARY**

ROOFING SYSTEM SUMMARY:	
NEMO Type:	B-1; Mechanically Fixed Insulation, Bonded Coverboard; Bonded Roof Cover
Cap Ply:	Oxidized asphaltic sheet or SBS modified bitumen, cold-adhesive applied
Ply:	(Optional) Oxidized asphaltic sheet or SBS modified bitumen, cold-adhesive applied
Base Ply:	Oxidized asphaltic sheet or SBS modified bitumen, cold-adhesive applied
Coverboard:	Asphaltic-based, cement-based or gypsum-based board, adhesive-applied
Insulation (mid):	(Optional) Polyisocyanurate foam board, adhesive-applied
Insulation (base):	Polyisocyanurate foam board, mechanically fixed
Vapor Barrier:	Any approved type, loose-laid, adhered or mechanically fixed
Thermal Barrier:	(Optional) Any approved type, loose-laid, adhered or mechanically fixed
Deck:	Wood or steel

DYNAMIC UPLIFT RESISTANCE PER CSA A123.21:					
Sustained Test Value		Design Value CSA A123.21:20 (Test Value x 0.65)		Design Value CSA A123.21:14 (Test Value ÷ 1.5)	
kPa	psf	kPa	psf	kPa	psf
-3,6	-75	-2,3	-49	-2,4	-50

PRODUCTS / APPLICATION:		
Surfacing: (Optional)	Description:	Surfacing applied for fire classification performance and/or reflectivity.
	Application:	Cold-applied, hot-applied or fluid-applied
	Eligible Products:	Any Tremco hot-applied or cold-applied flood coat and gravel or aggregate stone, or Tremco roof coating approved for use with the cap ply membrane, applied in accordance with Tremco requirements.
Cap Ply:	Description:	Membrane composed of fiberglass reinforcement coated with oxidized bitumen or fiberglass, fiberglass/polyester composite or polyester reinforcement coated with SBS modified bitumen
	Application:	BURmastic Adhesive or POWERply Standard Cold Adhesive, full-coverage, 2.0 gal/square
	Eligible Products:	BURmastic Glass Ply, BURmastic Glass Ply – 28 lb, BURmastic Composite Ply HT, BURmastic Composite Ply Premium, BURmastic Composite Ply HT Green, POWERply Standard Smooth, POWERply Heavy Duty Base, POWERply 2PM, POWERply Endure 300 FR, POWERply Endure 320 FR, POWERply Standard, POWERply Standard FR, POWERply Standard FR GT24C, POWERply Endure 100 FR, POWERply 3GR or POWERply Endure 200 FR

**ROOF SYSTEM ASSESSMENT REPORT, DYNAMIC UPLIFT RESISTANCE PER CSA A123.21**

CUSTOMER: Tremco CPG, Inc. PUBLICATION DATE: 2025-10-27  
 DOCUMENT NO. TRM-PARS-7 REVISION NO. 0  
 REEVALUATION DATE: 2028-10-27



PRODUCTS / APPLICATION:				
Ply: (Optional)	Description:	Membrane composed of fiberglass reinforcement coated with oxidized bitumen or fiberglass, fiberglass/polyester composite or polyester reinforcement coated with SBS modified bitumen		
	Application:	BURmastic Adhesive or POWERply Standard Cold Adhesive, full-coverage, 2.0 gal/square		
	Eligible Products:	One or more BURmastic Glass Ply, BURmastic Glass Ply – 28 lb, BURmastic Composite Ply HT, BURmastic Composite Ply Premium, BURmastic Composite Ply HT Green, POWERply Endure 300 Smooth, POWERply Endure 320 Smooth, POWERply Standard Smooth, POWERply Endure 100 Smooth, POWERply Heavy Duty Base, POWERply 2PM or POWERply Endure 200 Smooth		
Base Ply:	Description:	Membrane composed of fiberglass reinforcement coated with oxidized bitumen or fiberglass, fiberglass/polyester composite or polyester reinforcement coated with SBS modified bitumen		
	Application:	BURmastic Adhesive or POWERply Standard Cold Adhesive, full-coverage, 2.0 gal/square		
	Eligible Products:	BURmastic Glass Ply, BURmastic Glass Ply – 28 lb, BURmastic Composite Ply HT, BURmastic Composite Ply Premium, BURmastic Composite Ply HT Green, POWERply Endure 300 Smooth, POWERply Endure 320 Smooth, POWERply Standard Smooth, POWERply Endure 100 Smooth, POWERply Heavy Duty Base, POWERply 2PM or POWERply Endure 200 Smooth		
Coverboard:	Description:	Asphaltic-based, cement-based or gypsum-based board		
	Application:	Adhesive-applied		
	Eligible Products:	<b>By</b>	<b>Product</b>	<b>Thickness</b>
		Tremco	Tremboard AC	Min. 3.2-mm (0.125-inch)
		Blue Ridge Fiberboard	Sturdy-Dek Asphaltic Cover Board	
		USG	SECUROCK Cement Roof Board	Min. 12.7-mm (0.5-inch)
		Georgia-Pacific Gypsum	DensDeck Prime	Min. 6.4-mm (0.25-inch)
National Gypsum		DEXcell FA Glass Mat Roof Board		
USG	SECUROCK Gypsum-Fiber Roof Board			
Coverboard Adhesive:	Description:	Polyurethane based insulation adhesive		
	Application:	Continuous ribbons, max. 305-mm (12-inch) on-center		
	Eligible Products:	<b>By</b>	<b>Product</b>	
		Tremco CPG	Low Rise Foam Insulation Adhesive, Low Rise Foam Insulation Adhesive (BG) or Tremco PSF Adhesive	
HB Fuller Company	Millennium One Step Foamable Adhesive or Millennium PG-1 Pump Grade Adhesive			
Insulation, mid layer(s): (Optional)	Description:	Polyisocyanurate foam board laminated on both sides with fiber reinforced felt or coated fiberglass facer		
	Application:	One or more layer(s), adhesive-applied		
	Eligible Products:	<b>By</b>	<b>Product</b>	<b>Dimensions</b>
		Tremco CPG	Trisotech, Trisotech G or Trisotech CGF	Max. 1.2 x 1.2-m (4 x 4 ft) x min. 25-mm (1-inch) thick
		Amrize / Elevate	ISOGARD GL or ISOGARD CG	
		Atlas Roofing	ACFoam II or ACFoam III	
		GAF	EnergyGuard Polyiso Insulation	
		Hunter Panels	H-Shield	
Johns Manville		ENRGY 3		
Rmax Ltd	Multi-Max FA3 or UltraMax			

**ROOF SYSTEM ASSESSMENT REPORT, DYNAMIC UPLIFT RESISTANCE PER CSA A123.21**

CUSTOMER: Tremco CPG, Inc. PUBLICATION DATE: 2025-10-27  
 DOCUMENT NO. TRM-PARS-7 REVISION NO. 0  
 REEVALUATION DATE: 2028-10-27



PRODUCTS / APPLICATION:				
Insulation, mid layer, Adhesive:	Description:	Polyurethane based insulation adhesive		
	Application:	Continuous ribbons, max. 305-mm (12-inch) on-center		
	Eligible Products:	<b>By</b>	<b>Product</b>	
		Tremco CPG	Low Rise Foam Insulation Adhesive, Low Rise Foam Insulation Adhesive (BG) or Tremco PSF Adhesive	
HB Fuller Company	Millennium One Step Foamable Adhesive or Millennium PG-1 Pump Grade Adhesive			
Insulation, base layer:	Description:	Polyisocyanurate foam board laminated on both sides with fiber reinforced felt or coated fiberglass facer		
	Dimensions:	Min. 1.2 x 2.4-m (4 x 8 ft) or 1.2 x 1.2-m (4 x 4 ft) x thickness noted below		
	Application:	Optional base layer(s) loose laid, top layer mechanically fixed		
	Eligible Products:	<b>By</b>	<b>Products</b>	<b>Min. Top Layer Thickness</b>
		Tremco CPG	Trisotech, Trisotech G or Trisotech CGF	50.8-mm (2-inch)
		Amrize / Elevate	ISOGARD GL or ISOGARD CG	
		Atlas Roofing	ACFoam II or ACFoam III	
		GAF	EnergyGuard Polyiso Insulation	
Hunter Panels		H-Shield		
Johns Manville		ENRGY 3		
Rmax Ltd	Multi-Max FA3 or UltraMax			
Insulation Fasteners:	Description:	Corrosion resistant screw-type roofing fasteners with steel stress plates		
	Fastening Method:	Fasteners installed through stress plates to engage the top flanges of the steel deck		
	Fastener Density:	1 per 2 ft <sup>2</sup> (16 parts per 4x8 ft board or 8 parts per 4x4 ft board)		
	Eligible Products:	<b>By</b>	<b>Product</b>	
		Tremco CPG	Tremco #12 DP, Tremco #14 HD or Tremco #15 EHD with Tremco 3" Metal Insulation Plate	
Altenloh, Brink & Co US		Trufast #12 DP, Trufast #14 HD or Trufast #15 EHD with Trufast 3" Metal Insulation Plate		
OMG	OMG #12 Standard Roofgrip, OMG #14 Heavy Duty or OMG XHD with OMG 3 in. Ribbed Galvalume Plate			

**ROOF SYSTEM ASSESSMENT REPORT, DYNAMIC UPLIFT RESISTANCE PER CSA A123.21**

CUSTOMER:	Tremco CPG, Inc.	PUBLICATION DATE:	2025-10-27
DOCUMENT NO.	TRM-PARS-7	REVISION NO.	0
		REEVALUATION DATE:	2028-10-27



PRODUCTS / APPLICATION:		
Vapour Barrier: <i>(Optional)</i>	Description:	Min. 6-mil polyethylene or other vapor barrier
	Application:	Loose-laid, adhered or mechanically-attached
	Eligible Products:	Any approved product acceptable to Tremco and the Authority Having Jurisdiction
Thermal Barrier: <i>(Optional)</i>	Description:	Cement-based, gypsum-based or mineral-wool board
	Application:	Loose-laid, adhered or mechanically-attached
	Eligible Products:	Any approved product acceptable to Tremco and the Authority Having Jurisdiction
Deck:	As-Tested:	Plywood roof deck
	Extended:	Steel roof deck

NOTES:				
Test Value and Design Value:	The "Test Value" noted herein reflects the ultimate passing test pressure recorded during testing. The "Design Value" herein reflects the "Test Value" multiplied by a resistance factor of 0.65, or divided by a safety factor of 1.5. The "Design Value" should meet or exceed the design pressure requirements of the project, as determined in accordance with the current National Building Code of Canada (NBC) requirements.			
Equivalence of Other Products:	This report applies only to the products listed as "Eligible Products" herein.			
Optional Components:	Components listed herein as "optional" may be removed from the roof system design with no adverse effect on system dynamic wind uplift performance.			
As-Tested Deck:	Testing utilized plywood, APA rated sheathing, 40/20, Exposure 1, PS1, 19/32 category, CDX. Results extended to use of min. 22 ga., Type B (6-inch deck module) steel deck meeting ASTM A653, A792, A1008 or CSSBI 10M standard and having a yield strength of 275 MPa (40-ksi) based on previous testing (TRM-D1). Alternate deck displaying equivalent strength and fastener-holding capacity (withdrawal resistance) may be specified at the discretion of the Designer of Record to the satisfaction of the Authority Having Jurisdiction.			
Fastener Point-Loads:	<b>Point-Load</b>			
	<b>Sustained Test Value</b>		<b>Design Value</b>	
	<b>N</b>	<b>lbf</b>	<b>N</b>	<b>lbf</b>
	667	150	434	98

**ROOF SYSTEM ASSESSMENT REPORT, DYNAMIC UPLIFT RESISTANCE PER CSA A123.21**

CUSTOMER:	Tremco CPG, Inc.	PUBLICATION DATE:	2025-10-27
DOCUMENT NO.	TRM-PARS-7	REVISION NO.	0
		REEVALUATION DATE:	2028-10-27



Page 5 of 5

**RSAR SCOPE**

**Roof System Assessment Reports (RSAR)** constitute a summary of allowable products and interfaces used in low-slope roof assemblies based testing in accordance with CSA A123.21 at our ISO/IEC 17025 accredited laboratory.

While RSAR's are reviewed and renewed each 3-years based primarily on report holder declaration, these are not Certification listings, and are not intended to state or imply ongoing quality control / surveillance activities by NEMO at the report holder's facilities.

NEMO ETC, LLC is not, in any way, the Designer of Record for any project on which these RSAR's, or previous versions thereof, is/was used for permitting or design guidance. RSAR's are not to be construed as representing any attributes not specifically listed, nor to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by NEMO ETC, LLC, express or implied, as to any finding or other matter in these RSAR's, or as to any product covered by the RSAR's.

**NEMO ETC CREDENTIALS**

TYPE	ENTITY	REFERENCE
ISO/IEC 17025 Accreditation	International Accreditation Service (IAS)	<a href="#">TL-689</a>
TAS 301 Certification	Miami-Dade	<a href="#">21-0409.01</a>
Third Party Test Data Program	UL, LLC	<a href="#">DA2862</a>
Test Lab Listing	Roofing Contractors Association of British Columbia	<a href="#">RCABC Labs</a>

**REPORT HISTORY**

DATE	EVENT	NOTES	AUTHORIZED BY:
2025-10-24	DRAFT 1	For customer review	RN
2025-10-27	FINAL	After customer review	RN

This report and the data contained therein is the sole property of NEMO|etc. and the named customer. This report shall not be reproduced outside NEMO|etc. except by the named customer without written permission by the named customer, in which case the report shall be reproduced in its entirety.

**END OF REPORT**